

JULY 8, 2010

RFP 09028IM E-RISER 50 MICRON REPLACEMENT

Response to Questions 1

ATTENTION ALL PROPONENTS:

This notification is being provided to all proponents as GHS's response to the following vendor questions.

QUESTION:

Will there be a pre bid meeting or walk through for this project? If not, would it be possible to get floor plans for estimating purposes?

GHS RESPONSE:

Please review Exhibit #1 GHS FLOOR PLANS.

Please note the following:

- 1) The blue closets in the E-wing of the hospital is the E-Riser where the vertical fiber will come through.**
- 2) On GMH 11, the pattern shaded blue labeled data center is the proposed location for terminating all the fibers.**
- 3) The yellow dots represents the horizontal closets on each floor**

QUESTION:

Are you looking for the contractor to provide a CommScope warranty?

GHS RESPONSE:

Fiber comes with manufacturers warranty and the vendor should guarantee the installation as well. Thus, warranty is intrinsic and not something you buy separately.

All other Terms & Conditions remain the same.

Please acknowledge receipt of this addendum on Appendix C of the RFP.